WALTON COUNTY
BUILDING DEPARTMENT

ENVELOPE LEAKAGE TEST REPORT
BLOWER DOOR TEST

Permit: _____

Contractors Name: _____

Job Address: _____

City _____ Zip _____

Air Leakage Test Results Passing results must be 7 ACH (50) or less

The building thermal envelope shall be constructed to limit air leakage in accordance with Sections R402.4.1 through R402.4.4 of the Florida Energy Code. The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 7 air changes per hour in Climate Zone 1 and 2. Testing shall be conducted with a blower door at a pressure of 0.2 inches w.g. (50 Pascals).

_____ x 60 ÷ _____= _____
CFM (50) Building Volume ACH (50)

☐ **PASS** ☐ **FAIL**

Method for calculating building volume:
☐ Retrieved from architectural plans
☐ Code software calculated
☐ Field measured and calculated

☐ When ACH (50) is less than 3, Mechanical Ventilation installation must be verified by the Building Department

Testing Company

I hereby certify that the above test results demonstrate compliance with energy code requirements in accordance with 2020 Florida Building Energy Conservation Code:

_____ _____
Printed Name of Certified Person Performing Test Signature

_____ _____
Date of Test License/Certification Number

This form must be on file with the Building Department before requesting C/O inspection.

05/24/2022